



**Environmental and Laboratory Services**  
 90 ½ West Blackwell St., Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: May 26, 2017  
 Address: Montville Township School District  
 86 River Road  
 Montville, NJ 07045

**Project: Cedar Hill School**

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5390-1  
 Sample location: FIELD BLANK  
 Sampled by: D. Mitchell  
 Sample date: 05/06/17  
 Time: 08:20  
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:22	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5390-2  
 Sample location: CH-MO-NURSE  
 Sampled by: D. Mitchell  
 Sample date: 05/06/17  
 Time: 08:23  
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:27	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5390-3  
 Sample location: CH-FB-BY 12  
 Sampled by: D. Mitchell  
 Sample date: 05/06/17  
 Time: 08:24  
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:33	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5390-4  
 Sample location: CH-TL-TEACHER LOUNGE  
 Sampled by: D. Mitchell  
 Sample date: 05/06/17  
 Time: 08:25  
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.00 µg/L	15 µg/L	05/19/17	20:38	1	2.00 µg/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS5390-5  
 Sample location: CH-FC-BY MULTIPURPOSE RM  
 Sampled by: D. Mitchell  
 Sample date: 05/06/17  
 Time: 08:26  
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:44	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen  
 Susan VanVeen, Lab Manager  
 NJ Laboratory Certification ID # 14013

5/28/17  
 Date

# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

#	Asc./HCl Vials	pH:	_____
#	HCl Vials	pH:	_____
#	Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> :	_____
#	5 HNO <sub>3</sub> (250 ml)	pH:	4.2 ✓
#	H <sub>2</sub> SO <sub>4</sub>	pH:	_____
#	NaOH	pH:	_____
#	unpreserved		_____
#	other		_____
#	other		_____

Customer Name: CEDAR HILL	report to:	Agra Environmental Services
Address: 46 PINE BROOK RD MONTVILLE NJ	Nicole Mangili	90½ West Blackwell Street Dover, NJ 07801
County/Municipality:	Nicole.Mangili@Montville.net	Phone: (973) 989-0010
Phone: Richard Medwin		Fax: (973) 989-0156
Work:		

**Matrix Abbreviations:** D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
	DW5539D										
Field Blank		5/6/17	0820	x			1	NH03	1ST DRAW PB <2 ug/L 5/19/17	2022	SM
CH-MO-NURSE		5/6/17	0823	x			1	NH03	1ST DRAW PB <2 ug/L	2027	
CH-FB-BY 12		5/6/17	0824	x			1	NH03	1ST DRAW PB <2 ug/L	2033	
CH-TL-TEACHER LOUNGE		5/6/17	0825	x			1	NH03	1ST DRAW PB 2.0 ug/L	2038	
CH-FC-BY MULTIPURPOSE RM		5/6/17	0826	x			1	NH03	1ST DRAW PB <2 ug/L	2044	
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		

Sampled By (name/company): <i>D. Mitchell</i>	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013					
	NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>D. Mitchell</i>	Date: 5/6/17	Time: 0930	Received By: <i>[Signature]</i>	Date: 5/8/17	Time: 0831	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No