



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 26, 2017
 Address: Montville Township School District
 86 River Road
 Montville, NJ 07045

Project: William Mason School

Sample description: Drinking Water / 1st Draw / DWS5395-1
 Sample location: FIELD BLANK
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	19:36	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-2
 Sample location: WM-FC-BY 17
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:48
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	19:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-3
 Sample location: WM-FC-BY NURSE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:49
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	19:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-4
 Sample location: WM-MO-NURSE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:50
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.62 µg/L	15 µg/L	05/19/17	19:59	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-5
 Sample location: WM-TL-TEACHER LOUNGE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:52
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:05	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-6
 Sample location: WM-FC-BY 01
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:53
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:10	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5395-7
 Sample location: WM-FC-BY 32
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 07:54
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	20:16	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

5/28/17
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

_____ Asc./HCl Vials pH: _____
 # _____ HCl Vials pH: _____
 # _____ Na₂S₂O₃ Cl₂: _____
 # 7 HNO₃ (250ml) pH: 2.2 ✓
 # _____ H₂SO₄ pH: _____
 # _____ NaOH pH: _____
 # _____ unpreserved _____
 # _____ other _____
 # _____ other _____

Customer Name: WILLIAM MASON	report to:	Agra Environmental Services
Address: 5 SHAWNEED TRAIL		90½ West Blackwell Street
MONTVILLE NJ	Nicole Mangili	Dover, NJ 07801
County/Municipality:	Nicole.Mangili@Montville.net	Phone: (973) 989-0010
Phone: Richard Medwin		Fax: (973) 989-0156
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
	DW55395										
Field Blank		5/6/17	0745	x			1	NH03	1ST DRAW PB <2 µg/L 5/9/17	1936	BM
WM-FC-BY 17		5/6/17	0748	x			1	NH03	1ST DRAW PB <2 µg/L	1942	
WM-FC-BY-NURSE		5/6/17	0749	x			1	NH03	1ST DRAW PB <2 µg/L	1948	
WM-MO-NURSE		5/6/17	0750	x			1	NH03	1ST DRAW PB 4.62 µg/L	1959	
WM-TL-TEACHERS LOUNGE		5/6/17	0752	x			1	NH03	1ST DRAW PB <2 µg/L	2005	
WM-FC-BY 01		5/6/17	0753	x			1	NH03	1ST DRAW PB <2 µg/L	2010	
WM-FC-BY 32		5/6/17	0754	x			1	NH03	1ST DRAW PB <2 µg/L	2016	
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		
		5/6/17		x			1	NH03	1ST DRAW PB		

Sampled By (name/company): <i>Dan J. [Signature]</i>	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013					
	NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>Dan J. [Signature]</i>	Date: 5/6/17	Time: 0953	Received By: <i>[Signature]</i>	Date: 5/8/17	Time: 0832	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No