



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 26, 2017
 Address: Montville Township School District
 86 River Road
 Montville, NJ 07045

Project: Woodmount School

Sample description: Drinking Water / 1st Draw / DWS5392-1
 Sample location: FIELD BLANK
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:13
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	16:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5392-2
 Sample location: WD-FC-BY NURSE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	16:43	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5392-3
 Sample location: WD-MO-NURSE
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:16
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	9.00 µg/L	15 µg/L	05/19/17	16:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5392-4
 Sample location: WD-FC-BY 09
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	16:54	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5392-5
 Sample location: WD-FC BY 19
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:19
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.00 µg/L	15 µg/L	05/19/17	17:00	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5392-6
 Sample location: WD-TL-19
 Sampled by: D. Mitchell
 Sample date: 05/06/17
 Time: 09:19
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/19/17	17:05	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

5/28/17
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

_____ Asc./HCl Vials pH: _____
 # _____ HCl Vials pH: _____
 # _____ Na₂S₂O₃ Cl₂: _____
 # 6 HNO₃ (250 mL) pH: 4.2 ✓
 # _____ H₂SO₄ pH: _____
 # _____ NaOH pH: _____
 # _____ unpreserved _____
 # _____ other _____
 # _____ other _____

Customer Name: WOODMOUNT	report to:	Agra Environmental Services
Address: 39 WOODMOUNT AVE		90½ West Blackwell Street
MONTVILLE	Nicole Mangili	Dover, NJ 07801
County/Municipality:	Nicole.Mangili@Montville.net	Phone: (973) 989-0010
Phone: Richard Medwin		Fax: (973) 989-0156
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
	<u>DW35392</u>										
Field Blank	<u>1</u>	5/6/17	<u>0913</u>	x			1	NHO3	1ST DRAW PB < 2 ug/L	<u>5/19/17</u>	<u>1621</u> <u>SM</u>
WD-FC-BY NURSE	<u>2</u>	5/6/17	<u>0914</u>	x			1	NHO3	1ST DRAW PB < 2 ug/L		<u>1643</u>
WD-MO-NURSE	<u>3</u>	5/6/17	<u>0916</u>	x			1	NHO3	1ST DRAW PB 9.00 ug/L		<u>1649</u>
WD-FC-BY-09	<u>4</u>	5/6/17	<u>0917</u>	x			1	NHO3	1ST DRAW PB < 2 ug/L		<u>1654</u>
WD-FC-BY-19	<u>5</u>	5/6/17	<u>0919</u>	x			1	NHO3	1ST DRAW PB 3.00 ug/L		<u>1700</u>
WD-TL-19	<u>6</u>	5/6/17	<u>0919</u>	x			1	NHO3	1ST DRAW PB < 2 ug/L		<u>1705</u>
		5/6/17		x			1	NHO3	1ST DRAW PB		
		5/6/17		x			1	NHO3	1ST DRAW PB		
		5/6/17		x			1	NHO3	1ST DRAW PB		
		5/6/17		x			1	NHO3	1ST DRAW PB		

Sampled By (name/company): D. Smith

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box):

Standard NJ Reduced Other (Specify) _____

Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <u>D. Smith</u>	Date: <u>5/6/17</u>	Time: <u>0958</u>	Received By: <u>[Signature]</u>	Date: <u>5/8/17</u>	Time: <u>0833</u>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____ Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No